

## Fire Comment\_Markup Summary - 79539 - 904 E highland Dr

**6702554-CN Fire Review : Cycle 2**  
Shawn Shepherd, PE (Fire Protection Engineer)  
E: shawn.shepherd@seattle.gov  
P: 206-386-1446

### Fire (3)



**Subject:** General  
**Page Index:** 2  
**Author:** Shepherd  
**X:** 16.2584 in  
**Y:** 13.0182 in  
**Layer:** Review Comment  
**Review Type:** Fire

Revise to indicate fire alarm system as deferred submittal. Revise Sprinkler & Fire Suppression Systems line item to include the required standpipe system



90 **Subject:** Standpipe  
90 **Page Index:** 10  
**Author:** Shepherd  
**X:** 8.4484 in  
**Y:** 18.0309 in  
**Layer:** Review Comment  
**Review Type:** Fire

Revise the plans to indicate installation of a Class I standpipe system as required by 2015 Seattle Fire Code section 905.3.



**Subject:** General  
**Page Index:** 10  
**Author:** Shepherd  
**X:** 19.8817 in  
**Y:** 1.1807 in  
**Layer:** Review Comment  
**Review Type:** Fire

Revise note as an emergency responder radio coverage system is not required for this building.